

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 12/20/2007  
FORM APPROVED  
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  <b>344002</b>		(X2) MULTIPLE CONSTRUCTION A. BUILDING <b>04 - MORRISON</b> B. WING _____		(X3) DATE SURVEY COMPLETED  <b>08/23/2007</b>	
NAME OF PROVIDER OR SUPPLIER  <b>BROUGHTON HOSP</b>				STREET ADDRESS, CITY, STATE, ZIP CODE <b>1000 S STERLING ST MORGANTON, NC 28655</b>			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
K 025	<p><b>NFPA 101 LIFE SAFETY CODE STANDARD</b></p> <p>Smoke barriers are constructed to provide at least a one half hour fire resistance rating in accordance with 8.3. Smoke barriers may terminate at an atrium wall. Windows are protected by fire-rated glazing or by wired glass panels and steel frames. A minimum of two separate compartments are provided on each floor. Dampers are not required in duct penetrations of smoke barriers in fully ducted heating, ventilating, and air conditioning systems. 19.3.7.3, 19.3.7.5, 19.1.6.3, 19.1.6.4</p> <p>This STANDARD is not met as evidenced by: Based on observation, on August 23, 2007 at approximately 9:30am onward, the smoke barrier adjacent to room 202 is incomplete. There are holes where duct penetrates required smoke barrier.</p> <p>Note: This building is not fully sprinklered - smoke dampers are required in duct penetrations of required smoke barrier.</p>			K 025			

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Any deficiency statement ending with an asterisk (\*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.